



Certificate of
constancy of performance
0063-CPR-242190025
Issue: 00



Issued 24-01-2025 Replaces
First issued Page 1 / 3

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description: Alarm Transmission System
Trademark: AddSecure
Type designation: Airborne DC Dual Medium
Serial No: NA
Hardware / Software: STC00310rxx / 1.30.25.rel
Conditions and essential characteristics: See Annex 1
Variants: See Annex 1

placed on the market under the name or trademark of:

Name of the manufacturer: AddSecure AS
Address: Østensjøveien 14
City: 0661 OSLO
Country: Norway

and produced in the manufacturing plant(s):

Manufacturing plant: Tri-T Digital Display (Shenzhen) Company Limited
Address: 4-5/F, Block A, Zhao Feng Industrial Estate, San Wei Village
City: Xixiang Town, Baoan, Shenzhen
Country: China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-21:2006
EN 54-4:1997
EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006
EN 54-4:1997/AC:1999

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**

This certificate was first issued on and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers
Managing director

CERTIFICATE

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

Notified Body No. 0063



Remarks and observations

The following conditions are applicable:

Essential characteristics of EN 54-21:	Clauses:	Performance:
Performance of transmission	4, 5, 6	Pass
Operational reliability	4, 5, 6, 7, 8, 9	Pass
Durability of operational reliability: temperature resistance	10.4	Pass
Durability of operational reliability; vibration resistance	10.6, 10.7, 10.11	Pass
Durability of operational reliability; humidity resistance	10.5, 10.10	Pass
Durability of operational reliability; corrosion resistance	10.6	Pass
Durability of operational reliability; electrical stability	10.8, 10.9	Pass

Essential characteristics of EN 54-4:	Clauses:	Performance:
Performance of power supply	4, 5, 6	Pass
Operational reliability	4, 5, 6, 7, 8, 9.3	Pass
Durability of operational reliability temperature resistance	9.5, 9.6	Pass
Durability of operational reliability vibration resistance	9.7, 9.8, 9.15	Pass
Durability of operational reliability electrical stability	9.9 to 9.13	Pass
Durability of operational reliability humidity resistance	9.6, 9.14	Pass

The x visible in the hw version stands for a digit that can change in case of minor changes.
The certified version is recorded in the certification file together with any reported minor changes.

The product as described in this certificate includes the following type designations

- Product description:	Alarm Transmission System
- Trademark:	AddSecure
- Type designation:	Airborne DC
- Hardware version:	STC00275rxx
- Software version:	1.30.25.rel
- Serial number:	NA

-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC Medium
 - Hardware version: STC00276rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC E-Medium
 - Hardware version: STC00337rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC8
 - Hardware version: STC00293rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC8 Medium
 - Hardware version: STC00294rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC8 E-Medium
 - Hardware version: STC00302rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC Dual
 - Hardware version: STC00309rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC Dual Medium
 - Hardware version: STC00310rxx
 - Software version: 1.30.25.rel
 - Serial number: NA
-
- Product description: Alarm Transmission System
 - Trademark: AddSecure
 - Type designation: Airborne DC Dual E-Medium
 - Hardware version: STC00341rxx
 - Software version: 1.30.25.rel
 - Serial number: NA